


Blackwell



This Seal applies only to the design of structural elements.

2006 ALBERTA BUILDING CODE REQUIREMENTS

9.8.8.3 Height of Guards

- 1) Except as provided in Sentences (2) to (4), all guards shall be not less than 1070MM (3ft 6 in) high.
- (2) All guards within dwelling units shall be not less than 900 mm (2 ft 11in) high.
- (3) Exterior guards serving not more than one dwelling unit shall be not less than 900 mm (2 ft 11in) high where the walking surface served by the guard is not more than 1800 mm (5 ft 11 in) above the finished ground level.
- (4) Guards for flights of steps, except in required exit stairs, shall be not less than 900 mm (2 ft 11 in) high.
- (5) The height of guards for flights of steps shall be measured vertically from a line drawn through the leading edge of the treads served by the guard.

9.8.8.5. Openings In Guards

- (1) Except as provided in Sentence (2), openings through any guard that is required by Article 9.8.8.1. shall be of a size that will prevent the passage of a spherical object having a diameter of 100 mm (4 in) unless it can be shown that the location and size of openings that exceed this limit do not represent a hazard.

Refer to TimberTech Installation Guide for additional installation information.

This document is valid for one year from issue date. It may be renewable on an annual basis. Our ABC compliance calculations compared data obtained from: Architectural Testing Reports: Architectural Testing Reports No.65314.01-119-19 dated APR.10-2008 and No.79283.01-119-19 dated APR.09-2008.

| 2006 ALBERTA BUILDING CODE REQUIREMENTS | ARCHITECTURAL TESTING COMPLIANCE REFERENCE |
|--|--|
| PART 9 – RESIDENTIAL USE (FROM Table 9.8.8.2 Specified Loads for Guards) | (Test Series No. & Test No.) |
| Horizontal Load Applied Inward or Outward at any Point at the Top of the Guard: 0.75 kN/m (52 lb/ft) or concentrated load of 1.0 kN (224 lb) applied at any point | Test Series No.1 – Test No.3 Test Series No.3 – Test No.5 |
| Horizontal Load Applied Inward or Outward on Elements Within the Guard, Including Solid Panels and Pickets: Concentrated load of 0.5 kN (112 lb) applied at any point on individual elements | Test Series No.3 – Test No.1 & 2 |
| Evenly Distributed Vertical Load Applied at the Top of the Guard: 1.5 kN/m (103 lb/ft) | Test Series No.3 – Test No.4 |

Radiance Rail System

$\frac{3}{4}'' = 1' - 0''$

| REVISION | DATE | DESCRIPTION | BY | PAR |
|----------|-----------|-----------------------------|----|-----|
| 0 | APR.22/13 | ISSUED FOR A.B.C COMPLIANCE | | |


CLIENT: TIMBERTECH LIMITED
894 PRARIE AVENUE
WILMINGTON, OHIO 45177

NOM DU PROJET: PROJECT NAME: ARCHITECTURAL TESTING ALBERTA BUILDING CODE COMPLIANCE

TITRE: RADIANCE RAIL COMPOSITE GUARDRAIL SYSTEM

BY: B.K. CHECKED: J.S. SCALE: AS NOTED DATE: JAN.21/13

PROJECT NO.: BD2013-01-21 PROJECT NO.: BD-TT-RR-2A



Bryte Designs

134 JARVIS STREET, SECOND FLOOR
TORONTO, ON M5B 2B5
TEL: 416-638-1932
FAX: 416-638-7305