

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 8110-2042:0500 Page 1 of 1

**CATEGORY:** 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)

**LISTEE:** AZEK BUILDING PRODUCTS 894 Prairie Ave, Wilmington, OH 45177  
Contact: Chip Herr (937) 655-5297  
Email: chip.herr@azekco.com

**DESIGN:** TimberTech EDGE Premier Square Edge composite decking, material 0.89" x 5.36", 1/8" edge to edge gap spacing.

Refer to the manufacturer's installation instructions and product data sheets.

**RATING:** Class B Flame Spread

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee name, model number, rating, and SFM label.

**APPROVAL:** Listed as decking materials for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Test Protocol SFM 12-7A-4A

04-01-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*