

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 8110-2051:0003

**CATEGORY:** 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)

**LISTEE:** TimberTech Ltd.894 Prairie Avenue, Wilmington, OH 45177  
Contact: Charles Herr (937) 655-5297 Fax (937) 655-5241  
Email: cherr@timbertech.com

**DESIGN:** "ReliaBoard™" HDPE composite deck board, square edge, scalloped back surface, 3/4" at thinnest portion, 15/16" at thickest, 5-3/8" wide and nominally 2.4 lb/lineal foot. . Refer to the manufacturer's installation instructions and product data sheets.

**RATING:** Class B Flame Spread.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee name, Model number, rating and SFM label.

**APPROVAL:** Listed as decking materials for use in the Wildland Urban Interface areas.

**NOTE:** Test Protocol 12-7A-4A

Page 1 of 1

9-1-11 MT



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

*Listing Expires* **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*