

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	8110-2042:0501	
CATEGORY:	8110 - DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)	
LISTEE:	AZEK BUILDING PRODUCTS 894 Prairie Ave, Wilmington, OH, 45177 Contact: Fiume, Michael 3306188514 Email: michael.fiume@azekco.com	
DESIGN:	TimberTech Pro Reserve Square Edge Composite Decking, material 0.938" x 5.36" edge to edge spacing. Attached to nominal 2" x 6" Douglas fir joists, 16" O.C.	
	Refer to manufacturer's installation instructions and product data sheets.	
RATING:	Class C Flame Spread	
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.	
MARKING:	Listee's name, model number, rating, and SFM label.	
APPROVAL:	Listed as decking materials for use in the Wildland Urban Interface areas when attached exterior wall covering is also composed of noncombustible or ignition-resistant material. Refer to listee's Installation Instruction Manual for details.	
NOTES:	Test Protocol SFM 12-7A-4A	

04-21-20 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/08/2024 Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator Fire Engineering & Investigations Division



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE